

No. 78 : C.B.S.E. : C.F.O : B W Z : 2023

O/o. The Chief Fire Officer
Bangalore West, Sheshadri Road,
Highground Fire Station Premises
Bangalore - 560 009. Dt. 20/6/23

To,

The Chairman,
S.G.International Public School,
No. 18, Saraswathipuram,
Nandini layout, Bangalore-560 096.

Sir,

Sub : Advice on requirement of fire prevention, fire fighting & evacuation measures maintained : required to S.G.International Public School, No. 18, Saraswathi-Puram, Nandini layout, Bangalore-560 096.

Ref : Request letter Dt.

-----<<<<<<<<<>>>>>>>>-----
With reference to the subject above cited, I wish to state that the premises of S.G.International Public School having 2 Buildings (Old Building & New Building) each comprising ground floor and 3 upper floors situated at No. 18, Saraswathipura, Nandini layout, Bangalore was inspected by the Regional fire officer, Bangalore west range on with respect to fire prevention, fire fighting and evacuation point of view and has submitted the details as under;

A. Details of the building / premises :-

- | | | | |
|-----|------------------------------------|---|---|
| 01. | Address of the premises | : | M/s. S.G.International Public School,
No. 18, Saraswathipura, Nandini layout,
Bangalore-560 096. |
| 02. | Number of building | : | 02 Buildings (Old Building & New Building) |
| 03. | Number of floor | : | Each Building comprising Ground floor and
three upper floors. |
| 04. | Floor-wise details of occupancy :- | | |
| | Old Building : | | |
| | Ground floor | : | Councilor room, Nursery A & B rooms,
Principal room, Secretary room & Chairman
road. |
| | 1 st floor | : | PT room, 3 rd A & B 2 rooms, 2 nd A & B rooms
& 6 th A & B 2 rooms. |


CHAIRMAN
SHRUTHI SAGARA VIDYA SAMSTHE (P)
No. 18, Saraswathipuram, 2nd Floor,
Nandini Layout, Bangalore-560 096


SG International Public School
No. 18, Saraswathipuram,
Nandini Layout, Bangalore-560 096
Ph: 080-23497428

- 2nd floor : Staff room, 4th A & B 2rooms, 5th A & B 2 rooms & 8th class room.
- 3rd floor : Vice Principal + staff room, 7th A & B 2 rooms, 9th A & B 2 rooms, language room & grade 10th room.
- New Building :
- Ground : Music room, Art & craft room & LKG A,B & C class rooms.
- 1st floor : UKG A, B & C class rooms, 1st A, B & C class rooms.
- 2nd floor : Library room & computer lab room.
- 3rd floor : Science lab.
05. Height of the building : Old Building : 14.30 Mtrs.
New Building : 14.30 Mtrs.
06. Site area : 2454.49 Sq.Mtrs.
07. Built-up area of each floor :-
- Old Building :
- Ground floor : 308.53 Sq.Mtrs.
- 1st floor : 308.53 Sq.Mtrs.
- 2nd floor : 308.53 Sq.Mtrs.
- 3rd floor : 308.53 Sq.Mtrs.
- New Building :
- Ground floor : 271.27 Sq.Mtrs.
- 1st floor : 271.27 Sq.Mtrs.
- 2nd floor : 271.27 Sq.Mtrs.
- 3rd floor : 271.27 Sq.Mtrs.
08. **Total Built-up area** : **Old Building** : 1234.12 Sq.Mtrs.
New Building : 1085.08 Sq.Mtrs.
09. Type of construction : RCC Building.
10. Surrounding properties :-
- North : 40 feet 2nd main road.
- South : Residential area.
- East : Mahalakshmpura tent road.
- West : SFS quarters.

11. Name and address of the building owner : Palnethra,
M/s. S.G International Public School,
No. 18, Saraswathipura, Nandini layout,
Bangalore-560 096.
12. Name and address of applicant : The Chairman,
M/s. S.G International Public School,
No. 18, Saraswathipuram, Nandini
layout, Bangalore-560 096.

B. On inspection of the school premises, the following fire prevention, fire fighting & evacuation measures are recommended and are absolutely essential:-

Sl. No.	Details [02]	Existing [03]	Recommendations [04]
01.	Approach to the Premises.	The premises is accessible from 12.00 Mtrs. wide road located on the northern side and hard enough to carry the weight of 45,000 kgs. capacity.	The requirement is complied with
02.	Entrance to the premises	2 entrance, one of 3.50 Mtrs. wide and another of 2.00 Mtrs. width has been provided for the movement of emergency vehicles.	The requirement is complied with.
03.	No of staircases	02 staircases have been provided in both the Buildings.	The requirement is Complied with.
04.	Portable fire extinguishers		
	Ground floor to 3 rd floor	1 ABC powder fire extinguishers each of 5 kgs. capacity have been provided in Both the Buildings.	In addition to the existing fire extinguishers, one more ABC type fire extinguishers each of 5 kgs. capacity should be provided near the corridors of each floors of each Building.

05. Fire precautionary measures: -

- A. The exit ways shall be kept clear always without any obstructions.
- B. The exit ways shall be marked with using illuminating paint.
- C. No fire in any form shall be used in the premises.
- D. Inflammable and explosive materials should not be stored in the area.
- E. 'No Smoking' boards shall be displayed at appropriate places in the premises.
- F. 2 emergency lights covering the floors shall be installed.
- G. The doors shall not be kept locked / latched during working hours.

06.	Escape routes	Directions in which the students have to move in the event of an emergency shall be displayed in the corridor written in bold letters and luminous paint.	The requirement is complied with.
07.	First aid boxes	01 first aid boxes near each floors near the staircases of each Building has been provided.	The requirement is complied with.
08.	Fire alarm system	Not installed.	Manually operated electrical fire alarm system should be installed with call boxes located near each staircase landing. The call boxes should be of "break glass" type, where the call is transmitted automatically to the control room when the glass of the system is broken. This system should also be connected to an alternative source of power supply (Diesel generator). The call boxes should be so installed that their location can be easily noticed from either direction and should be at a height of one meter from the floor level.

FIRE SAFETY CERTIFICATE

No.

Dated: 20/4/23

Certified that the S.G. INTERNATIONAL Public School (name of the building or premises) at Nandini Layout B-96 (address) comprised of I. Ground floor basement(s) and II. Middle floor (upper floors) owned/occupied by III. 4th floor (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on IV. 20.4.23 (date of inspection) in the presence of Mrs. Sunanda V. (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy class KG to Secondary school with effect from 20-4-23 for a period of 5 years in accordance with rule and subject to compliance of the conditions.


Issued on 20.4.23 at _____ by _____

* Strike out whichever is not applicable.

Signature with Seal : _____

Name Hanumanthappa Yours faithfully

Designation



Chief Fire Officer
Bangalore West, Sheshadri Road,
Highground Fire Station Premises,
Bangalore - 560 009.

To

S G INTERNATIONAL PUBLIC SCHOOL
18, SARASWATHI PURAM
NANDINI LAYOUT, BANGALORE
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to _____

_____ (reasons to be recorded).

Name and designation of the authorized signatory)


CHAIRMAN
SHRIJITHI SAGARA VIDYA SAMSTHE (P)
C-12, Saraswathipuram 2nd Cross,
Nandini Layout, Bangalore-560008